

**cross-over**

item number	for width of cable tray	for height of cable tray	B	thickness of metal sheet
<b>NKR 50X62</b>	62	50	465	0,8
<b>NKR 50X125</b>	125	50	528	0,8
<b>NKR 50X250</b>	250	50	653	1,0
<b>NKR 100X125</b>	125	100	528	0,8
<b>NKR 100X250</b>	250	100	653	1,0



**product description:** The cross-over is used to connect cable trays that cross over on one level running through cable trays MARS of the same width.

Unequal cross there is possible to replace by use of reductive parts NRD.

To fix the connection use the bolt NSM 6X10. To protect the cables, the bolt head is inside the cable tray.

A bolt with a GMT surface finish is used for a tray with an F surface finish.

Accessories may be covered according to the description given in the Systems with Maintained Functionality during Fires catalogue.

**configuration:** S - Pre-Galvanized, zinc-layer 15 - 27 µm  
F - Hot Dip Galvanized, zinc-layer 50 - 100 µm

**sales amount:** á 1 pc

**certification:** EN 61537:02

**classification:** ZP 27/2008 ..... P90-R  
DIN 41012-12 .... E90  
STN 92 0205 ..... PS 90

Fire classification is depend on the specific conditions of the cable tray, detailed in the catalog Systems with maintained functionality in fire.

Systems may be supplied with various surface finishes whereas the surface finish does not affect the determined maintained time of operability in fire.

**storage:** EN 60721-3-1

