## bolt to concrete



type number: SB 6.3X35

product description: It serves for attaching OMEGA clamps or independent cable

clamps to the base material.

The bolt may be mounted in concrete, natural stone, or solid

brickwork.

 $\mathsf{A} \oslash \mathsf{5}$  mm hole needs to be pre-drilled for mounting of the bolt.

The surface finish supplied is the equivalent of galvanized zinc and may be used to attach clamps or brackets with a different finish.

configuration: GMT - non electrolytic plating, aluminum-zinc-layer 5-15  $\mu m$ 

(equivalent Hot Dip Galvanized)

sales amount: á 100 pc

classification: ZP 27/2008 ...... P90-R

DIN 41012-12 .... E90 STN 92 0205 ..... PS 90

Fire classification is depend on the specific conditions of the cable tray, detailed in the catalog Systems with maintained functionality

in fire.

storage: EN 60721-3-1

